

October 13, 2009

HUFFCUTT CONCRETE, INC.
BILL OLSON
4154 123RD ST
CHIPPEWA FALLS WI 54729

Re: Description: SEWAGE TREATMENT APPARATUS, TANK/CONTAINER ONLY
Manufacturer: HUFFCUTT CONCRETE, INC.
Product Name: **SEPTIC/ ECOPOD - D models 300D, 350D, 400D and 450D.**
Model Number(s): 5000 GAL. FOR ECOPOD-D COMMERCIAL WW TREATMENT UNITS, ECOPOD D-SERIES MODELS: 300D, 350D, 400D, and 450D
[62.5 IN. L.L.; 71.9 GALS./IN.; 96 IN. MAX. DEPTH OF BURY; 5213 GALS. ACTUAL CAPACITY; TANK DIMENSIONS = 200.5 IN. L X 99 IN. W X 93 IN. H]
Product File No: 20090301

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is approved to use the following:
 - Four, six or eight inch inlet and outlet openings.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Pipe materials constructed in conformance with COMM Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - A 12-inch access port for holding tanks.
 - Four inch discharge opening in riser.
 - Optional 6-12-24- inch concrete risers.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Metal lockdown cover.
 - Cast-A-Seal and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- **This approval remains in effect while the DELTA ECOPOD - D MODELS 300D, 350D, 400D AND 450D WW TREATMENT UNITS have current approvals.**

October 13, 2009

- **For treatment credits in residential and commercial POWTS designs, see stipulations regarding max. CBOD5, DWF, approved effluent filters, etc. contained in approval letters for ECOPOD-D COMMERCIAL WW TREATMENT UNITS, ECOPOD D-SERIES MODELS: 300D, 350D, 400D, and 450D.**
- Additional information is included as attachment(s) to this letter; see attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov

Attachment A.